

SOUTHERN NEVADA REGIONAL INTERPRETATION

DATE: August 11, 2011

CODE: 2009 IBC 2008 NEC LOCAL AMENDMENTS
2009 IRC 2009 UMC POOL CODE
2009 IECC 2009 UPC

CODE SECTION: 2008 NEC Article 690.14 (C) (1) Additional Provisions (amended)

Delete the exception and revise Article 690.14(C) (1), as follows:

(1) Location. The photovoltaic disconnecting means and overcurrent device shall be installed at an accessible location on the outside of a building or structure before any system conductors enter the building or structure.

TOPIC (Description): Photovoltaic disconnecting means and overcurrent device location.

PURPOSE/REASON: To provide consistent interpretation and enforcement of photovoltaic disconnecting means and overcurrent device location.

INTERPRETATION: The intent of this code amendment is to provide an accessible disconnect as applied to wiring methods and not as applied to equipment and therefore it may be accessible and not required to be readily accessible.

LIMITATIONS: This interpretation is applicable to the following jurisdictions.

Boulder City Don Byrd
Clark County [Signature]
Henderson Mohammed Tadi
Las Vegas Christ Light
Mesquite _____
North Las Vegas Suey W. Black
Nye County _____
Clark County School District [Signature]