

Errata for ISPSC

As for the Amendments section 324.2 Pool or spa location. Any pool or spa shall not be placed closer than 60 inches to any **window to a** building or structure and shall not encroach within public utility easements.

The requirement for windows is in section 307.1.1 it was put in here by mistake and needs to be deleted out

324.2 remove the words “window to a”